



TAMPER RESISTANT DUPLEX RECEPTACLE WITH (2) 5 Amp 5 VDC USB PORT CHARGER

Installation Instructions

GENERAL INFORMATION

1. **NOTICE:** For installation by a qualified electrician in accordance with the national and local electrical codes and the following instructions.
2. **CAUTION: RISK OF ELECTRIC SHOCK.** Disconnect power before installing.
3. **CAUTION:** USE COPPER CONDUCTORS ONLY.
4. Check that the device's type and rating are suitable for the application.
5. The green light (LED) is "ON" when the USB ports are powered.
6. This device is to be installed in a wall box measuring at least 3" x 2" x 2-1/2" (standard single gang electrical wall box), raceway, power pole, furniture box, table top box, etc. and wired in accordance with NEC Article 314 box fill requirements.
7. The USB ports can supply up to 5A DC to the connected devices.

INSTALLATION

1. Terminal capacity #14 AWG to #10 AWG.
2. See the back of device for the stripping gauge.
3. Connect conductors to the proper terminals as follow:
 - * Green or Bare to Green Hex Screw.
 - * White or Gray to White Screw.
 - * Black or Red to Brass Screw.
4. Tighten terminal screws to 10-12 lb•in (1.1-1.4 N•m).
5. Mount the receptacle to the box, and attach the wall plate. Place the provided "USB charger" label if needed.

* This equipment has been tested and found to comply with the limits for a Class B digital device, pursuant to part 15 of the FCC Rules. These limits are designed to provide reasonable protection against harmful interference in a residential installation.

